

April 20, 2016

**BSE Limited** 

Floor 25, P J Towers, Dalal Street, Mumbai – 400 001

Scrip Code: 533096

National Stock Exchange of India Limited

Exchange Plaza, Bandra Kurla Complex, Bandra (E), Mumbai – 400 051

Scrip Code: ADANIPOWER

Dear Sir,

Sub.: Regulation 30 (Disclosure of events or information) – Securities and Exchange Board of India (Listing Obligations and Disclosure Requirements) Regulations, 2015.

Please find attached a copy of the Statement being sent to the media.

Kindly take this on your record.

For Adani Power Limited

Deepak Pandya Company Secretary

Adani Power Ltd Achalraj Opp. Mayor Bunglow, Law Garden, Ahmedabad – 380 006 Gujarat, India CIN: L40100GJ1996PLC030533 Tel +91 79 2555 7555 Fax +91 79 2555 7177 info@adani.com www.adani.com adani

Adani Power Limited

Media Statement

Today, during start-up, after two day's shut down, in one of the nine units of Mundra Power plant, hot water splashed from the vent of a flash tank. During the start up some steam is normally allowed to vent.

During this process 21 workmen working in the said unit have been affected by the splashing of hot water, the unit has been shut down. Eight workmen with nominal injuries have been provided first aid and released; balance 13 workmen who have suffered various levels of injuries are being provided high quality medical care by moving them to premier super-speciality hospitals in Ahmedabad which have capabilities to take best care of the workmen affected.

The company has constituted a multi-disciplinary, cross-functional team of experts to investigate the incident and submit report within 10 days.



Adani Power Ltd Achalraj Opp. Mayor Bunglow, Law Garden, Ahmedabad – 380 006 Gujarat, India CIN: L40100GJ1996PLC030533 Tel +91 79 2555 7555 Fax +91 79 2555 7177 info@adani.com www.adani.com